

Unregulated Contaminants

The U.S. Environmental Protection Agency required some water systems and cities to take samples in 2023 for an assessment monitoring program for the Unregulated Contaminant Monitoring Rule 5 (UCMR5). The EPA will review the findings of this nationwide assessment to determine if any new regulations are needed.

Atlantic Municipal Utilities UCMR 5 Sample Results

Sample Event Code/Sample Schedule	SE1	Feb 2024
Facility ID/Name	ATLANTIC MUNICIPAL UTILITIES	01
Sample Point ID/Type/Name	01 EP	CLEAR WELL

Analyte Name	Collection Date	Reported Value(µg/L)
PFTA	2/6/2024 12:00:00 AM	<0.008
Analyte Name	Collection Date	Reported Value(µg/L)
PFTTrDA	2/6/2024 12:00:00 AM	<0.007
Analyte Name	Collection Date	Reported Value(µg/L)
NEtFOSAA	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
NMeFOSAA	2/6/2024 12:00:00 AM	<0.006
Analyte Name	Collection Date	Reported Value(µg/L)
PFBS	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHpA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHxS	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFNA	2/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFOS	2/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFOA	2/6/2024 12:00:00 AM	<0.004

Analyte Name	Collection Date	Reported Value(µg/L)
PFDA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFDaA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHxA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFUxA	2/6/2024 12:00:00 AM	<0.002
Analyte Name	Collection Date	Reported Value(µg/L)
11Cl-PF3OUdS	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
9Cl-PF3ONS	2/6/2024 12:00:00 AM	<0.002
Analyte Name	Collection Date	Reported Value(µg/L)
ADONA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
HFPO-DA	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
PFBA	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
6:2 FTS	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
4:2 FTS	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
8:2 FTS	2/6/2024 12:00:00 AM	<0.005
Analyte Name	Collection Date	Reported Value(µg/L)
PFMPA	2/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFPeA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFMBA	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFEESA	2/6/2024 12:00:00 AM	0.003

Analyte Name	Collection Date	Reported Value(µg/L)
NFDHA	2/6/2024 12:00:00 AM	<0.02
Analyte Name	Collection Date	Reported Value(µg/L)
PFPeS	2/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFHpS	2/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
lithium	2/6/2024 12:00:00 AM	<9

Sample Event Code/Sample Schedule	SE2	Aug 2024
Facility ID/Name	ATLANTIC MUNICIPAL UTILITIES	01
Sample Point ID/Type/Name	01 EP	CLEAR WELL

Analyte Name	Collection Date	Reported Value(µg/L)
PFBS	8/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHpA	8/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHxS	8/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFNA	8/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFOS	8/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFOA	8/6/2024 12:00:00 AM	<0.004
Analyte Name	Collection Date	Reported Value(µg/L)
PFDA	8/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFDoA	8/6/2024 12:00:00 AM	<0.003
Analyte Name	Collection Date	Reported Value(µg/L)
PFHxA	8/6/2024 12:00:00 AM	<0.003

Analyte Name PFUnA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.002
Analyte Name 11CI-PF3OUdS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name 9CI-PF3ONS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.002
Analyte Name ADONA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name HFPO-DA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name PFBA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name 6:2 FTS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name 4:2 FTS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name 8:2 FTS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name PFMPA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.004
Analyte Name PFPeA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name PFMBA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name PFEESA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name NFDHA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.02

Analyte Name PFPeS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.004
Analyte Name PFHpS	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.003
Analyte Name PFTA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.008
Analyte Name PFTrDA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.007
Analyte Name NEtFOSAA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.005
Analyte Name NMeFOSAA	Collection Date 8/6/2024 12:00:00 AM	Reported Value(µg/L) <0.006